

TEST CERTIFICATE

No: C20/ 53889

Client

OE Electrics Ltd
Thomas Madison Lane
Calder Park
Wakefield
West Yorkshire
WF4 3GH

Client contact

Mr Charles Fox

Item(s) tested

Multi-Socket Outlet (German, French & Swiss)
Models: **Qikfit 2G, Qikfit 3G(German only)**
Rated: 16A, 250V ~


Specification(s) to which above unit(s) have been tested and compliance confirmed

All relevant clauses of **IEC 60884-1: 2002 +A1: 2006, +A2: 2013** including: **German, French & Swiss deviations** and deemed to **Comply**

Date of issue

2nd April 2020

Signed



Bunmi Phillips
(Certifying Officer)

Relating to Project File(s) held at Nemko Ltd

51082, 51295, 51334, 51530, 52252 & 53889

To be read in conjunction with page 2 attached



Form No: QF102-1
Issue No: 6
Issue Date: 08.03.16



Nemko Ltd

Certificate No:	C20/ 53889
Client:	OE Electrics Ltd

THIS CERTIFICATE APPLIES ONLY TO THE PARTICULAR SAMPLE UNIT(S) TESTED AND TO THE SPECIFIC TESTS CARRIED OUT AS DETAILED IN THE PROJECT FILE HELD AT NEMKO LTD.

THIS TEST CERTIFICATE DOES NOT COVER ELECTROMAGNETIC COMPATIBILITY.

IT SHOULD BE NOTED THAT ONLY A LIMITED NUMBER OF UNITS HAVE BEEN TESTED. IT IS THEREFORE ESSENTIAL FOR THE MANUFACTURER OR SUPPLIER OF THIS PRODUCT TO ENSURE THAT THE QUALITY OF ALL PRODUCTION UNITS IS OF THE SAME STANDARD AS THAT OF THE SAMPLE(S) CHECKED

Condition / number of test sample(s) : Good / 1 **Serial Number(s) :** -

Notes relating to this Certificate: -

- (i) The socket-outlets are rated for fixed or portable use; except for;
- (ii) In France the socket-outlet can only be used in portable application un-enclosed unless fitted with a secondary label or marking of the maximum power rating which is visible when a plug is engaged.

Project History: -

<u>Job Number</u>	<u>Sample received</u>	<u>Job Completion Date</u>	<u>Summary of work carried out</u>
51082	15-Jan-18	28-Feb-18	Full testing to IEC 60884-1:2002+A1:2006+A2:2013
51295	04-March-18	16-March-18	Re-test of project 51082
51334	15-Jan-18	29-June-18	Limited testing to IEC 61535: 2009 for connectors
51530	25-July-18	20-Sept-18	Re-test of project 51295
52252	23-Nov-18	05-Feb-19	Additional testing for fixed applications
53889	02-Mar-20	02-Apr-20	Addition of model: Qikfit 3G(German)

***** END OF CERTIFICATE *****

